

FAIR HAVEN FIRE MARSHAL'S OFFICE

January 14, 2022

Site Plan Review Re: Planning Board Application 21-05 – 626 River Rd B 31 L 01

Fire Hydrant Location: Existing Hydrant located on River Rd across from proposed project. Approx 50' away. ( Main size not indicated )


Fire Department Access / Fire Lane: Approved as specified on page TT-1 of Site Plan. Minimum 18" is required and is provided. " No Parking Fire Lane " signage and striping detail is provided on page DT-1 & DT-2 and is correct and approved. Page PS-1 specifies " No Parking Fire Lane " Striping placement. Where only one is indicated on this page, a second location for striping shall be provided more towards the dumpster enclosure.

Dumpster Enclosure : Proposed "Dumpster Enclosure" location is indicated on page PS-1 and is approved. Dumpster is indicated to be more than 5' from any combustible component of the building.

" FDC " Fire Department Connection for sprinkler and or standpipe location : Not indicated at this time.

Paul Murphy, NAFI-CFEI, IAAI-FIT, IAAI-ECT

Fire Marshal, Borough of Fair Haven

 1/14/2022